




### Isolux



### UGR-Diagramm

Corrected UGR values (at 7720 lm bare lamp luminous flux)												
Reflect.: ceiling/cav walls work pl. Room dim x y		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30	
		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30	
		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	
		viewed crosswise					viewed endwise					
2H	2H	24.8	25.6	25.1	25.8	26.0	24.8	25.6	25.1	25.8	26.0	
	3H	24.7	25.3	25.0	25.6	25.9	24.7	25.3	25.0	25.6	25.9	
	4H	24.6	25.2	25.0	25.5	25.8	24.6	25.2	25.0	25.5	25.8	
	6H	24.5	25.1	24.9	25.4	25.7	24.5	25.1	24.9	25.4	25.7	
	8H	24.5	25.0	24.9	25.4	25.7	24.5	25.0	24.9	25.4	25.7	
	12H	24.5	25.0	24.8	25.3	25.7	24.5	25.0	24.9	25.3	25.7	
4H	2H	24.6	25.2	25.0	25.5	25.8	24.6	25.2	25.0	25.5	25.8	
	3H	24.5	25.0	24.9	25.3	25.7	24.5	25.0	24.9	25.3	25.7	
	4H	24.4	24.8	24.8	25.2	25.6	24.4	24.8	24.8	25.2	25.6	
	6H	24.3	24.7	24.7	25.1	25.5	24.3	24.7	24.7	25.1	25.5	
	8H	24.3	24.6	24.7	25.0	25.5	24.3	24.6	24.7	25.0	25.5	
	12H	24.2	24.5	24.7	24.9	25.4	24.2	24.5	24.7	24.9	25.4	
8H	4H	24.3	24.6	24.7	25.0	25.5	24.3	24.6	24.7	25.0	25.5	
	6H	24.2	24.4	24.6	24.9	25.4	24.2	24.4	24.6	24.9	25.4	
	8H	24.1	24.4	24.6	24.8	25.3	24.1	24.4	24.6	24.8	25.3	
	12H	24.1	24.3	24.6	24.8	25.3	24.1	24.3	24.6	24.8	25.3	
12H	4H	24.2	24.5	24.7	24.9	25.4	24.2	24.5	24.7	24.9	25.4	
	6H	24.1	24.4	24.6	24.8	25.3	24.1	24.4	24.6	24.8	25.3	
	8H	24.1	24.3	24.6	24.8	25.3	24.1	24.3	24.6	24.8	25.3	
Variations with the observer position at spacing:												
S = 1.0H		3.3 / -15.9					3.3 / -15.9					
1.5H		6.0 / -22.8					6.0 / -22.8					
2.0H		8.0 / -27.9					8.0 / -27.9					