



**Wirkungsgrad**

R	77	75	73	71	55	53	33	00	DRR
K0.8	73	70	67	65	69	66	66	64	78
1.0	76	73	71	69	72	70	70	67	83
1.5	80	78	76	74	77	75	74	72	89
2.0	83	81	79	78	80	78	78	75	93
2.5	84	83	82	81	82	81	80	78	96
3.0	85	84	83	83	83	82	81	79	98
4.0	86	85	85	84	84	84	82	81	99
5.0	87	86	86	86	85	84	83	81	100

**UGR-Diagramm**

Corrected UGR values (at 1100 lm bare lamp luminous flux)											
Reflect.:		viewed crosswise					viewed endwise				
ceiling/cav		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim											
x	y										
2H	2H	-7.8	-7.3	-7.5	-7.1	-6.8	-7.8	-7.3	-7.5	-7.1	-6.8
	3H	-7.9	-7.5	-7.6	-7.2	-6.9	-7.9	-7.5	-7.6	-7.2	-6.9
	4H	-8.0	-7.6	-7.7	-7.3	-7.0	-8.0	-7.6	-7.7	-7.3	-7.0
	6H	-8.1	-7.7	-7.7	-7.4	-7.0	-8.1	-7.7	-7.7	-7.4	-7.1
	8H	-8.1	-7.7	-7.8	-7.4	-7.1	-8.1	-7.7	-7.8	-7.4	-7.1
	12H	-8.1	-7.8	-7.8	-7.4	-7.1	-8.2	-7.8	-7.8	-7.5	-7.1
4H	2H	-8.0	-7.6	-7.7	-7.3	-7.0	-8.0	-7.6	-7.7	-7.3	-7.0
	3H	-8.2	-7.8	-7.8	-7.5	-7.1	-8.2	-7.8	-7.8	-7.4	-7.1
	4H	-8.2	-7.9	-7.9	-7.6	-7.2	-8.2	-7.9	-7.9	-7.6	-7.2
	6H	-8.3	-8.0	-7.9	-7.6	-7.2	-8.3	-8.0	-7.9	-7.6	-7.2
	8H	-8.4	-8.1	-7.9	-7.7	-7.2	-8.4	-8.1	-7.9	-7.7	-7.3
	12H	-8.4	-8.2	-7.9	-7.7	-7.3	-8.4	-8.2	-8.0	-7.8	-7.3
8H	4H	-8.4	-8.1	-7.9	-7.7	-7.3	-8.4	-8.1	-7.9	-7.7	-7.2
	6H	-8.5	-8.2	-8.0	-7.8	-7.3	-8.4	-8.2	-8.0	-7.8	-7.3
	8H	-8.5	-8.3	-8.0	-7.8	-7.3	-8.5	-8.3	-8.0	-7.8	-7.3
	12H	-8.5	-8.3	-8.0	-7.9	-7.3	-8.5	-8.4	-8.0	-7.9	-7.4
12H	4H	-8.4	-8.2	-8.0	-7.8	-7.3	-8.4	-8.2	-7.9	-7.7	-7.3
	6H	-8.5	-8.3	-8.0	-7.9	-7.4	-8.5	-8.3	-8.0	-7.8	-7.3
	8H	-8.5	-8.4	-8.0	-7.9	-7.4	-8.5	-8.3	-8.0	-7.9	-7.3
Variations with the observer position at spacing:											
S =		1.0H	6.7 / -11.6				6.7 / -11.6				
		1.5H	9.6 / -12.2				9.6 / -12.2				
		2.0H	11.5 / -12.6				11.5 / -12.6				