



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2019011001221615

NAME AND ADDRESS OF THE APPLICANT

iGuzzini illuminazione S.p.A.
Via Mariano Guzzini, 37 62019 Recanati, Italy

NAME AND ADDRESS OF THE MANUFACTURER

iGuzzini illuminazione S.p.A.
Via Mariano Guzzini, 37 62019 Recanati, Italy

NAME AND LOCATION OF THE FACTORY

iGuzzini illuminazione S.p.A.
Via Mariano Guzzini, 37 62019 Recanati, Italy

PRODUCT NAME,MODEL AND SPECIFICATION

Recessed Luminaire For LED Modules (Controlled Port Dimming, Ceiling Recessed, A.C. Supplied
Electronic Controlgear For LED Modules, Class II , Exposed Part: IP23, Recessed Part: IP20, Suitable
For Direct Mounting On Normally Flammable Material, Not Covered By Insulating Material)
QK62 23.5W(1×21W/LED) , QK63 13.5W(1×12W/LED) , QK67 13.5W(1×12W/LED)). 220/240V ~ 50/60Hz

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 17625.1-2022;GB/T 17743-2021;GB 7000.1-2015;GB 7000.202-2008

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C10-01:2014).

Valid from: Feb.08,2025

Valid until: Feb.07,2030

Date of original issued: Aug.26,2019

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





中国国家强制性产品认证证书

证书编号: 2019011001221615

认证委托人名称及地址

iGuzzini illuminazione S.p.A.
Via Mariano Guzzini, 37 62019 Recanati, 意大利

生产者名称及地址

iGuzzini illuminazione S.p.A.
Via Mariano Guzzini, 37 62019 Recanati, 意大利

生产企业名称及地址

iGuzzini illuminazione S.p.A.
Via Mariano Guzzini, 37 62019 Recanati, 意大利

产品名称和系列、型号、规格

嵌入式灯具 (控制端口调光, 嵌天花板式, LED 模块用交流电子控制装置, II 类, 外露部分: IP23, 嵌入部分: IP20, 适宜直接安装在普通可燃材料表面, 不能被隔热材料覆盖)

QK62 23.5W(1×21W/LED), QK63 13.5W(1×12W/LED), QK67 13.5W(1×12W/LED)。220/240V~ 50/60Hz

产品标准和技术要求

GB 17625.1-2022; GB/T 17743-2021; GB 7000.1-2015; GB 7000.202-2008

上述产品符合《强制性产品认证实施规则 照明电器》(CNCA-C10-01:2014)的要求, 特发此证。

发证日期: 2025 年 02 月 08 日 有效期至: 2030 年 02 月 07 日

本证书为变更证书, 证书首次颁发日期: 2019 年 08 月 26 日
证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。

经中国合格评定国家认可委员会认可 CNAS C001-P



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司

