





**Polare**



**Isolux**



**Diagramma UGR**

Corrected UGR values (at 2630 lm bare lamp luminous flux)											
Reflect.:		viewed crosswise					viewed endwise				
ceiling	cav	0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim		viewed crosswise					viewed endwise				
x	y										
2H	2H	0.9	1.5	1.2	1.7	1.9	0.7	1.2	1.0	1.5	1.7
	3H	0.8	1.3	1.1	1.6	1.8	0.6	1.1	0.9	1.3	1.6
	4H	0.7	1.2	1.1	1.5	1.8	0.5	1.0	0.8	1.3	1.5
	6H	0.7	1.1	1.0	1.4	1.7	0.4	0.9	0.8	1.2	1.5
	8H	0.6	1.0	1.0	1.4	1.7	0.4	0.8	0.8	1.1	1.5
12H	0.6	1.0	1.0	1.3	1.7	0.4	0.7	0.7	1.1	1.4	
4H	2H	0.7	1.2	1.1	1.5	1.8	0.5	1.0	0.9	1.3	1.6
	3H	0.6	1.0	1.0	1.3	1.7	0.4	0.8	0.8	1.1	1.5
	4H	0.5	0.9	0.9	1.2	1.6	0.3	0.6	0.7	1.0	1.4
	6H	0.4	0.7	0.9	1.1	1.5	0.2	0.5	0.6	0.9	1.3
	8H	0.4	0.7	0.8	1.1	1.5	0.2	0.4	0.6	0.9	1.3
12H	0.3	0.6	0.8	1.0	1.5	0.1	0.4	0.6	0.8	1.2	
8H	4H	0.4	0.7	0.8	1.1	1.5	0.2	0.4	0.6	0.9	1.3
	6H	0.3	0.5	0.8	1.0	1.4	0.1	0.3	0.5	0.7	1.2
	8H	0.2	0.4	0.7	0.9	1.4	0.0	0.2	0.5	0.7	1.2
	12H	0.2	0.4	0.7	0.8	1.4	-0.0	0.1	0.5	0.6	1.1
12H	4H	0.3	0.6	0.8	1.0	1.5	0.1	0.4	0.6	0.8	1.2
	6H	0.2	0.4	0.7	0.9	1.4	0.0	0.2	0.5	0.7	1.2
	8H	0.2	0.4	0.7	0.8	1.4	-0.0	0.1	0.5	0.6	1.1
Variations with the observer position at spacing:											
S =	1.0H	6.1 / -10.7					6.1 / -10.3				
	1.5H	8.9 / -12.6					8.9 / -12.2				
	2.0H	10.9 / -13.9					10.8 / -14.1				