





**Polare**



**Isolux**



**Diagramma UGR**

Corrected UGR values (at 2620 lm bare lamp luminous flux)											
Reflect.:		viewed crosswise					viewed endwise				
ceiling	cav	0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim											
x	y										
2H	2H	20.2	20.9	20.5	21.1	21.4	20.1	20.8	20.4	21.1	21.3
	3H	20.1	20.7	20.4	20.9	21.2	20.0	20.6	20.3	20.9	21.2
	4H	20.0	20.6	20.3	20.8	21.1	19.9	20.5	20.3	20.8	21.1
	6H	19.9	20.4	20.3	20.7	21.1	19.8	20.4	20.2	20.7	21.0
	8H	19.9	20.4	20.2	20.7	21.0	19.8	20.3	20.2	20.6	21.0
	12H	19.8	20.3	20.2	20.7	21.0	19.8	20.2	20.1	20.6	20.9
4H	2H	20.0	20.6	20.3	20.8	21.1	19.9	20.5	20.3	20.8	21.1
	3H	19.8	20.3	20.2	20.6	21.0	19.8	20.2	20.2	20.6	20.9
	4H	19.7	20.2	20.1	20.5	20.9	19.7	20.1	20.1	20.5	20.9
	6H	19.7	20.0	20.1	20.4	20.8	19.6	20.0	20.0	20.4	20.8
	8H	19.6	19.9	20.1	20.4	20.8	19.6	19.9	20.0	20.3	20.7
	12H	19.6	19.9	20.0	20.3	20.8	19.5	19.8	20.0	20.2	20.7
8H	4H	19.6	19.9	20.1	20.4	20.8	19.6	19.9	20.0	20.3	20.7
	6H	19.5	19.8	20.0	20.2	20.7	19.5	19.7	19.9	20.2	20.7
	8H	19.5	19.7	20.0	20.2	20.7	19.4	19.6	19.9	20.1	20.6
	12H	19.4	19.6	19.9	20.1	20.6	19.4	19.6	19.9	20.0	20.6
12H	4H	19.6	19.9	20.0	20.3	20.8	19.5	19.8	20.0	20.2	20.7
	6H	19.5	19.7	20.0	20.2	20.7	19.4	19.6	19.9	20.1	20.6
	8H	19.4	19.6	19.9	20.1	20.6	19.4	19.6	19.9	20.0	20.6
Variations with the observer position at spacing:											
S =	1.0H	4.5 / -18.3					4.4 / -18.4				
	1.5H	7.3 / -20.5					7.3 / -20.7				
	2.0H	9.3 / -21.7					9.3 / -22.1				