



Polardiagramm



Isolux



UGR-Diagramm

Corrected UGR values (at 3500 lm bare lamp luminous flux)											
Reflect.:		viewed crosswise					viewed endwise				
ceiling	cav	0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim											
x	y										
2H	2H	20.7	21.4	21.0	21.7	21.9	20.7	21.4	21.0	21.6	21.9
	3H	20.6	21.3	20.9	21.5	21.8	20.6	21.2	20.9	21.5	21.8
	4H	20.6	21.1	20.9	21.4	21.7	20.5	21.1	20.9	21.4	21.7
	6H	20.5	21.0	20.9	21.3	21.7	20.5	21.0	20.8	21.3	21.6
	8H	20.5	21.0	20.8	21.3	21.6	20.4	20.9	20.8	21.3	21.6
	12H	20.4	20.9	20.8	21.3	21.6	20.4	20.9	20.8	21.2	21.6
4H	2H	20.6	21.1	20.9	21.4	21.7	20.5	21.1	20.9	21.4	21.7
	3H	20.5	20.9	20.8	21.3	21.6	20.4	20.9	20.8	21.3	21.6
	4H	20.4	20.8	20.8	21.2	21.6	20.4	20.8	20.8	21.2	21.6
	6H	20.3	20.7	20.7	21.1	21.5	20.3	20.7	20.7	21.1	21.5
	8H	20.3	20.6	20.7	21.0	21.5	20.2	20.6	20.7	21.0	21.4
	12H	20.2	20.5	20.7	21.0	21.4	20.2	20.5	20.7	20.9	21.4
8H	4H	20.3	20.6	20.7	21.0	21.5	20.3	20.6	20.7	21.0	21.5
	6H	20.2	20.5	20.7	20.9	21.4	20.2	20.5	20.6	20.9	21.4
	8H	20.1	20.4	20.6	20.9	21.4	20.1	20.4	20.6	20.8	21.3
	12H	20.1	20.3	20.6	20.8	21.3	20.1	20.3	20.6	20.8	21.3
12H	4H	20.2	20.5	20.7	21.0	21.4	20.2	20.5	20.7	20.9	21.4
	6H	20.1	20.4	20.6	20.9	21.4	20.1	20.4	20.6	20.8	21.3
	8H	20.1	20.3	20.6	20.8	21.3	20.1	20.3	20.6	20.8	21.3
Variations with the observer position at spacing:											
S =		1.0H	2.7 / -0.9				2.7 / -0.6				
		1.5H	4.9 / -9.9				4.8 / -9.6				
		2.0H	6.9 / -11.1				6.8 / -10.8				