
Design Mario iGuzzini Cucinella

Last information update: April 2024

Product configuration: EQ07

EQ07: Outdoor ceiling-mounted luminaire - Neutral White LED - On/Off - Flood optic





Product code

EQ07: Outdoor ceiling-mounted luminaire - Neutral White LED - On/Off - Flood optic

Technical description

Ceiling-mounted luminaire designed to use Neutral White LED lamps with a Flood optic. The luminaire consists of an optical assembly/component-holding box and base for ceiling-mounting. The optical assembly, front frame, rear door and celing-mount base are made of die-cast aluminium alloy painted with a smooth finish (grey RAL 9007) or a textured finish (white RAL 9016). The painting process includes a multi-step, pre-treatment process, in which the main phases are degreasing, fluorozirconation (a protective surface film) and sealing (with a nano-structured silane layer). The next painting stage consists of a primer and a liquid acrylic paint, cured at 150°C, with a high level of weather and UV ray resistance. The tempered sodium-calcium glass cover has customised serigraphy, is 5mm thick, and joined to the frame with silicone. The frame is fastened to the optical assembly by two M5 AISI 304 stainless steel captive screws and a steel safety cable. The product comes complete with a Neutral White colour, monochrome LED circuit, an optic with a 99.93% pure aluminium Opti Beam Reflector reflector with a polished, anodized surface and built-in electronic ballast. The component-holding box, in the rear of the luminaire, is set up to hold the control gear, which is fixed with captive screws on a galvanised steel pull-out plate. The control gear can be accessed via the ceiling-mounting base with quick-connecting system and the rear door made of painted aluminium alloy, fixed to the product. The internal silicone seals guarantee watertightness IP66h Set up for pass-through wiring using two (PG 11) nickel-plated brass cable glands, designed for cables with diameters between 6.5 and 11 mm. The connection to the mains is made using a 3-pole terminal block with a quick-coupling system. Cables with quick-coupling terminals connect the terminal block and the control gear. All external screws used are made of A2 stainless steel. The luminaire technical characteristics conform to EN60598-1 standards and particular requirements.

Installation

Ceiling-mounted using the special base. Secure using screw anchors for concrete, cement and solid brick.

Colour	Weight (Kg)
White (01) Black (04) Grey (15) Rust Brown (F5)	3.2

Mounting

ceiling surface|free standing

Wiring


Control gear complete with electronic ballast 120 ÷ 240V ac 50/60Hz.

Notes


Luminaire fitted with On/Off control gear.

Technical data				
Im system:	1523	Life Time LED 2:	100,000h - L90 - B10 (Ta 40°C)	
W system:	13.9	Voltage [Vin]:	230	
Im source:	1880	Lamp code:	LED	
W source:	12	Number of lamps for optical	1	
Luminous efficiency (lm/W,	109.6	assembly:		
real value):		ZVEI Code:	LED	
Im in emergency mode:	-	Number of optical	1	
Total light flux at or above	0	assemblies:		
an angle of 90° [Lm]:		Intervallo temperatura	from -25°C to 50°C.	
Light Output Ratio (L.O.R.)	81	ambiente:		
[%]:		Power factor:	See installation instructions	
Beam angle [°]:	44°	Inrush current:	5 A / 50 μs	
CRI (minimum):	80	Maximum number of		
Colour temperature [K]:	4000	luminaires of this type per	B10A: 31 luminaires B16A: 50 luminaires C10A: 52 luminaires C16A: 85 luminaires	
MacAdam Step:	2	miniature circuit breaker:		
Life Time LED 1:	100,000h - L90 - B10 (Ta 25°C)			
		Overveltess protections		
		Overvoltage protection:	4kV Common mode & 2kV Differential mode	
		Control:	On/off	

Polar



Isolux



UGR diagram

4H	v ol.	0.70 0.50 0.20 -0.6 -0.8 -0.8 -0.9 -1.0 -0.8 -1.0	-0.1 -0.2 -0.4 -0.5 -0.5 -0.6	0.50 0.50 0.20 viewed crosswis -0.3 -0.4 -0.5 -0.6 -0.6 -0.6		0.30 0.30 0.20 0.4 0.3 0.2 0.2 0.1 0.1	0.70 0.50 0.20 -0.7 -0.8 -0.9 -1.0 -1.0	-0.1 -0.3 -0.4 -0.5 -0.6 -0.6	0.50 0.50 0.20 viewed endwise -0.4 -0.5 -0.6 -0.6 -0.7 -0.7	0.50 0.30 0.20 0.1 -0.0 -0.1 -0.2 -0.3	0.30 0.20 0.20 0.3 0.2 0.2 0.1 0.1
walls work pi Room o x 2H	2H 3H 4H 6H 8H 12H 2H 3H 4H	-0.6 -0.8 -0.8 -0.9 -0.9 -1.0	-0.1 -0.2 -0.4 -0.5 -0.6	0.50 0.20 viewed crosswis -0.3 -0.4 -0.5 -0.6 -0.6	0.30 0.20 e 0.2 0.0 -0.1 -0.2 -0.2	0.30 0.20 0.4 0.3 0.2 0.2 0.1	-0.7 -0.8 -0.9 -1.0 -1.0	-0.1 -0.3 -0.4 -0.5 -0.6	0.50 0.20 viewed endwise -0.4 -0.5 -0.6 -0.6	0.30 0.20 0.1 -0.0 -0.1 -0.2 -0.3	0.30 0.20 0.3 0.2 0.2 0.1 0.1
work pi Room o x 2H	2H 3H 4H 6H 8H 12H 2H 3H 4H	-0.6 -0.8 -0.8 -0.9 -0.9 -1.0	-0.1 -0.2 -0.4 -0.5 -0.5 -0.6	0.20 viewed crosswis -0.3 -0.4 -0.5 -0.6 -0.6	0.20 e 0.2 0.0 -0.1 -0.2 -0.2	0.20 0.4 0.3 0.2 0.2 0.1	-0.7 -0.8 -0.9 -1.0 -1.0	-0.1 -0.3 -0.4 -0.5 -0.6	0.20 viewed endwise -0.4 -0.5 -0.6 -0.6 -0.7	0.20 0.1 -0.0 -0.1 -0.2 -0.3	0.20 0.3 0.2 0.2 0.1
Room o	2H 3H 4H 6H 8H 12H 2H 3H 4H	-0.6 -0.8 -0.8 -0.9 -0.9 -1.0	-0.1 -0.2 -0.4 -0.5 -0.6 -0.6	-0.3 -0.4 -0.5 -0.6 -0.6	0.2 0.0 -0.1 -0.2 -0.2	0.4 0.3 0.2 0.2 0.1	-0.7 -0.8 -0.9 -1.0 -1.0	-0.1 -0.3 -0.4 -0.5 -0.6	-0.4 -0.5 -0.6 -0.7	0.1 -0.0 -0.1 -0.2 -0.3	0.3 0.2 0.2 0.1
2H	2H 3H 4H 6H 8H 12H 2H 3H 4H	-0.8 -0.9 -0.9 -1.0	-0.1 -0.2 -0.4 -0.5 -0.5 -0.6	-0.3 -0.4 -0.5 -0.6 -0.6	0.2 0.0 -0.1 -0.2 -0.2	0.3 0.2 0.2 0.1 0.1	-0.8 -0.9 -1.0 -1.0 -1.0	-0.1 -0.3 -0.4 -0.5 -0.6 -0.6	-0.4 -0.5 -0.6 -0.6	0.1 -0.0 -0.1 -0.2 -0.3	0.2 0.2 0.1 0.1
4H	3H 4H 6H 8H 12H 2H 3H 4H	-0.8 -0.9 -0.9 -1.0	-0.2 -0.4 -0.5 -0.5 -0.6	-0.4 -0.5 -0.6 -0.6 -0.6	0.0 -0.1 -0.2 -0.2 -0.2	0.3 0.2 0.2 0.1 0.1	-0.8 -0.9 -1.0 -1.0 -1.0	-0.3 -0.4 -0.5 -0.6 -0.6	-0.5 -0.6 -0.6 -0.7	-0.0 -0.1 -0.2 -0.3	0.2 0.2 0.1 0.1
4H	4H 6H 8H 12H 2H 3H 4H	-0.8 -0.9 -0.9 -1.0	-0.2 -0.4 -0.5 -0.5 -0.6	-0.5 -0.6 -0.6 -0.6	-0.1 -0.2 -0.2 -0.2	0.2 0.2 0.1 0.1	-0.8 -0.9 -1.0 -1.0 -1.0	-0.3 -0.4 -0.5 -0.6 -0.6	-0.6 -0.6 -0.7	-0.0 -0.1 -0.2 -0.3	0.2 0.2 0.1 0.1
4H	6H 8H 12H 2H 3H 4H	-0.9 -0.9 -1.0 -0.8 -1.0	-0.5 -0.5 -0.6 -0.4 -0.6	-0.5 -0.6 -0.6 -0.6	-0.1 -0.2 -0.2 -0.2	0.2 0.1 0.1	-1.0 -1.0 -1.0	-0.5 -0.6 -0.6	-0.6 -0.7	-0.1 -0.2 -0.3	0.2 0.1 0.1
4H	6H 8H 12H 2H 3H 4H	-0.9 -0.9 -1.0 -0.8 -1.0	-0.5 -0.5 -0.6 -0.4 -0.6	-0.6 -0.6 -0.6	-0.2 -0.2 -0.2	0.2 0.1 0.1	-1.0 -1.0 -1.0	-0.5 -0.6 -0.6	-0.6 -0.7	-0.2 -0.3	0.1
4H	12H 2H 3H 4H	-1.0 -0.8 -1.0	-0.6 -0.4 -0.6	-0.6 -0.5	-0.2	0.1	-1.0	-0.6			
4H	2H 3H 4H	-0.8 -1.0	-0.4 -0.6	-0.5	0.000	1000000	0.000	3,300	-0.7	-0.3	0.0
	3H 4H	-1.0	-0.6		-0.1	0.2	0.0	2000	10-100-541		
	4H	33050		-0.6			-0.9	-0.4	-0.6	-0.1	0.2
		-1.1		112	-0.2	0.1	-1.0	-0.6	-0.7	-0.3	0.0
	6H		-0.7	-0.7	-0.3	0.0	-1.1	8.0-	-0.7	-0.4	-0.0
		-1.2	8.0-	-0.7	-0.4	-0.0	-1.2	-0.9	8.0-	-0.5	-0.1
	HS	-1.2	-0.9	8.0-	-0.5	-0.1	-1.3	-1.0	8.0-	-0.6	-0.
8Н	12H	-1.2	-1.0	8.0-	-0.6	-0.1	-1.3	-1.1	-0.9	-0.6	-0.2
	4H	-1.2	-0.9	8.0-	-0.5	-0.1	-1.3	-1.0	8.0-	-0.6	-0.
	6H	-1.3	-1.1	8.0-	-0.6	-0.1	-1.4	-1.1	-0.9	-0.7	-0.2
	HS	-1.3	-1.1	-0.9	-0.7	-0.2	-1.4	-1.2	-0.9	-0.7	-0.3
	12H	-1.4	-1.2	-0.9	-0.7	-0.2	-1.5	-1.3	-1.0	8.0-	-0.3
12H	4H	-1.2	-1.0	8.0-	-0.6	-0.1	-1.3	-1.1	-0.9	-0.6	-0.2
	бН	-1.3	-1.1	-0.9	-0.7	-0.2	-1.4	-1.2	-0.9	-0.7	-0.3
	HS	-1.4	-1.2	-0.9	-0.7	-0.2	-1.5	-1.3	-1.0	8.0-	-0.3
Variatio	ons wi	th the ol	bserverp	osition	at spacir	ng:					
5 =	1.0H		7.	.0 / -16	.1			7.	0 / -16	0.0	
	1.5H		9	.8 / -16	.9		9.8 / -16.6				