




Wirkungsgrad

R	77	75	73	71	55	53	33	00	DRR
K0.8	54	47	43	40	47	43	42	38	53
1.0	58	52	48	45	51	48	47	43	60
1.5	64	60	56	53	59	56	55	51	71
2.0	68	64	61	59	63	61	60	56	78
2.5	70	67	65	63	66	64	63	60	83
3.0	71	69	67	65	68	66	65	62	86
4.0	73	71	70	68	70	68	67	64	89
5.0	74	72	71	70	71	70	69	66	91

Söllner-Diagramm



UGR-Diagramm

Corrected UGR values (at 1250 lm bare lamp luminous flux)											
Reflect.:		viewed crosswise					viewed endwise				
ceil/cav		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim		viewed crosswise					viewed endwise				
x	y										
2H	2H	15.1	16.1	15.4	16.3	16.6	16.2	17.2	16.5	17.4	17.7
	3H	15.8	16.7	16.2	17.0	17.3	16.4	17.3	16.8	17.6	17.9
	4H	16.2	17.0	16.5	17.3	17.6	16.5	17.3	16.8	17.6	17.9
	6H	16.5	17.2	16.8	17.6	17.9	16.4	17.2	16.8	17.5	17.9
	8H	16.6	17.3	17.0	17.6	18.0	16.4	17.1	16.8	17.5	17.8
12H	16.6	17.3	17.0	17.7	18.0	16.4	17.1	16.8	17.4	17.8	
4H	2H	15.5	16.4	15.9	16.7	17.0	17.1	17.9	17.4	18.2	18.5
	3H	16.4	17.1	16.8	17.5	17.8	17.5	18.1	17.8	18.5	18.9
	4H	16.8	17.5	17.3	17.8	18.2	17.6	18.2	18.0	18.6	19.0
	6H	17.3	17.8	17.7	18.2	18.6	17.7	18.2	18.1	18.6	19.0
	8H	17.4	17.9	17.8	18.3	18.8	17.7	18.2	18.1	18.6	19.0
12H	17.5	17.9	18.0	18.4	18.8	17.7	18.1	18.1	18.6	19.0	
8H	4H	17.0	17.5	17.4	17.9	18.4	18.0	18.5	18.4	18.9	19.3
	6H	17.5	18.0	18.0	18.4	18.9	18.2	18.6	18.7	19.0	19.5
	8H	17.8	18.1	18.3	18.6	19.1	18.3	18.6	18.8	19.1	19.6
	12H	17.9	18.2	18.4	18.7	19.3	18.3	18.6	18.8	19.1	19.7
12H	4H	17.0	17.5	17.5	17.9	18.3	18.0	18.5	18.5	18.9	19.4
	6H	17.6	17.9	18.1	18.4	18.9	18.3	18.6	18.8	19.1	19.6
	8H	17.8	18.2	18.4	18.6	19.2	18.4	18.7	18.9	19.2	19.7
Variations with the observer position at spacing:											
S =	1.0H	0.4 / -0.5					0.3 / -0.4				
	1.5H	0.5 / -1.0					0.7 / -1.2				
	2.0H	1.1 / -1.4					1.6 / -1.6				