


Polare



Isolux




Diagramma UGR

Corrected UGR values (at 4100 lm bare lamp luminous flux)																
Reflect.:		viewed crosswise					viewed endwise									
ceil/cav	walls	work pl.	Room dim	x	y	0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30	
2H	2H	18.9	19.5	19.2	19.8	20.0	18.9	19.5	19.2	19.8	20.0	18.9	19.5	19.2	19.8	20.1
	3H	19.0	19.6	19.3	19.9	20.1	18.9	19.5	19.2	19.8	20.1	18.9	19.5	19.2	19.8	20.1
	4H	19.0	19.5	19.3	19.8	20.1	18.9	19.4	19.2	19.7	20.0	18.9	19.4	19.2	19.7	20.0
	6H	18.9	19.4	19.3	19.7	20.1	18.8	19.3	19.2	19.6	20.0	18.8	19.3	19.2	19.6	20.0
	8H	18.9	19.4	19.3	19.7	20.0	18.8	19.3	19.2	19.6	19.9	18.8	19.3	19.2	19.6	19.9
	12H	18.9	19.3	19.2	19.7	20.0	18.8	19.2	19.1	19.6	19.9	18.8	19.2	19.1	19.6	19.9
4H	2H	18.9	19.4	19.2	19.7	20.0	19.0	19.5	19.3	19.8	20.1	19.0	19.5	19.3	19.8	20.1
	3H	19.1	19.5	19.4	19.9	20.2	19.1	19.5	19.4	19.9	20.2	19.1	19.5	19.4	19.9	20.2
	4H	19.0	19.4	19.4	19.8	20.2	19.0	19.4	19.4	19.8	20.2	19.0	19.4	19.4	19.8	20.2
	6H	19.0	19.3	19.4	19.7	20.2	19.0	19.3	19.4	19.7	20.2	19.0	19.3	19.4	19.7	20.2
	8H	18.9	19.3	19.4	19.7	20.1	19.0	19.3	19.4	19.7	20.1	19.0	19.3	19.4	19.7	20.1
	12H	18.9	19.2	19.3	19.6	20.1	18.9	19.2	19.4	19.6	20.1	18.9	19.2	19.4	19.6	20.1
8H	4H	19.0	19.3	19.4	19.7	20.1	18.9	19.3	19.4	19.7	20.1	18.9	19.3	19.4	19.7	20.1
	6H	18.9	19.2	19.4	19.6	20.1	18.9	19.2	19.4	19.6	20.1	18.9	19.2	19.4	19.6	20.1
	8H	18.8	19.1	19.3	19.5	20.0	18.8	19.1	19.3	19.5	20.0	18.8	19.1	19.3	19.5	20.0
	12H	18.8	19.0	19.3	19.5	20.0	18.8	19.0	19.3	19.5	20.0	18.8	19.0	19.3	19.5	20.0
12H	4H	18.9	19.2	19.4	19.6	20.1	18.9	19.2	19.3	19.6	20.1	18.9	19.2	19.3	19.6	20.1
	6H	18.8	19.1	19.3	19.5	20.0	18.8	19.1	19.3	19.5	20.0	18.8	19.1	19.3	19.5	20.0
	8H	18.8	19.0	19.3	19.5	20.0	18.8	19.0	19.3	19.5	20.0	18.8	19.0	19.3	19.5	20.0
Variations with the observer position at spacing:																
S =	1.0H	2.8 / -2.8					2.8 / -2.8									
	1.5H	5.1 / -4.3					5.1 / -4.3									
	2.0H	6.9 / -5.5					6.9 / -5.5									