


Polar



Isolux




Diagrama UGR

Corrected UGR values (at 2630 lm bare lamp luminous flux)											
Reflect.:		viewed crosswise					viewed endwise				
ceil/cav		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim											
x	y										
2H	2H	0.9	1.5	1.2	1.7	1.9	0.7	1.2	1.0	1.5	1.7
	3H	0.8	1.3	1.1	1.6	1.8	0.6	1.1	0.9	1.3	1.6
	4H	0.7	1.2	1.1	1.5	1.8	0.5	1.0	0.8	1.3	1.5
	6H	0.7	1.1	1.0	1.4	1.7	0.4	0.9	0.8	1.2	1.5
	8H	0.6	1.0	1.0	1.4	1.7	0.4	0.8	0.8	1.1	1.5
	12H	0.6	1.0	1.0	1.3	1.7	0.4	0.7	0.7	1.1	1.4
4H	2H	0.7	1.2	1.1	1.5	1.8	0.5	1.0	0.9	1.3	1.6
	3H	0.6	1.0	1.0	1.3	1.7	0.4	0.8	0.8	1.1	1.5
	4H	0.5	0.9	0.9	1.2	1.6	0.3	0.6	0.7	1.0	1.4
	6H	0.4	0.7	0.9	1.1	1.5	0.2	0.5	0.6	0.9	1.3
	8H	0.4	0.7	0.8	1.1	1.5	0.2	0.4	0.6	0.9	1.3
	12H	0.3	0.6	0.8	1.0	1.5	0.1	0.4	0.6	0.8	1.2
8H	4H	0.4	0.7	0.8	1.1	1.5	0.2	0.4	0.6	0.9	1.3
	6H	0.3	0.5	0.8	1.0	1.4	0.1	0.3	0.5	0.7	1.2
	8H	0.2	0.4	0.7	0.9	1.4	0.0	0.2	0.5	0.7	1.2
	12H	0.2	0.4	0.7	0.8	1.4	-0.0	0.1	0.5	0.6	1.1
12H	4H	0.3	0.6	0.8	1.0	1.5	0.1	0.4	0.6	0.8	1.2
	6H	0.2	0.4	0.7	0.9	1.4	0.0	0.2	0.5	0.7	1.2
	8H	0.2	0.4	0.7	0.8	1.4	-0.0	0.1	0.5	0.6	1.1
Variations with the observer position at spacing:											
S =	1.0H	6.1 / -10.7					6.1 / -10.3				
	1.5H	8.9 / -12.6					8.9 / -12.2				
	2.0H	10.9 / -13.9					10.8 / -14.1				